

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 422

Dated: 14/05/2026

It is certified that an inspection team headed by Mr. D.P. Singh Lab Incharge /  
Sub. Engineer

(Name of Officers with designation) from Mrs. Anita Jayant chemist PHED Gwalior.

(Name of Department/ Office) PHED inspected the The Radiant Higher Secondary  
School C.B.S.E. Guda-Gudi Ka Naka Road Gwalior m.p.

(Name & Address of the school) on 13/05/2026 (date of inspection) and on the basis of  
 Water Test Report (Attached) bearing No. 422 Dated

14/05/2026 of PHED District Water-Testing Laboratory Gwalior.  
 (PHED lab) certified that the The Radiant Higher Secondary School C.B.S.E. Gwalior,

(Name of school) has safe drinking water facilities for the students and members of staff of the  
 institution and is maintaining the hygienic sanitation condition in the school building & the campus as  
 per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One year [14/05/2026 to 13/05/2027]

D.P. Singh  
 Lab Incharge  
 District Water Testing Laboratory  
 P.H.E. Division, Gwalior (M.P.)

Signature with Seal

Name : D.P. Singh

Designation : Sub. Engineer / Lab. Incharge

Name & Address of the Office / Department : PHED  
Gwalior.

To

Principal  
The Radiant Higher Secondary  
School C.B.S.E. Gwalior m.p.

(Name & Address of the Institution)

**Public Health Engineering Department District Water- Testing  
Laboratory Gwalior**

**Test Report**

Type of sample: Water Sample		Particular of sample : collected / not collected by PHED	
Particular of sender:- PRINCIPAL THE RADIANT HR. SEC.SCHOOL GUDA-GUDI KA NAKA ROAD ,Gwalior ,M.P.			
Sample No.	Place of Collection and Details of Sample		Date of collection
1	Drinking Water		12.05.2026
2	-		-
3	-		-
4	-		-
Particular of Sample :			
Date of Receipt: 12.05.2026		Time of Receipt: 02:10 PM	
Lab Reference No:		Date of Analysis: 13.05.2026	

**Nature of Study – Chemical and Bacteriological Analysis**

S.N.	Characteristics	Unit	As Per BIS-10500-2012 For Drinking Water		RESULT			
			Acceptable Value	Permissible limit in the absence of alternate source	Sample 1	Sample 2	Sample 3	Sample 4
<b>PHYSICAL TEST</b>								
1	Turbidity	NTU	1.0	5.0	2.0	-	-	-
2	Color	Cobalt	5	15	-	-	-	-
3	Taste & Odour		Unobjectionable	Objectionable	Unobjectionable	-	-	-
4	Temperature	C°	-	-	-	-	-	-
<b>CHEMICAL TEST</b>								
5	PH Value	PH Scale	6.5 To 8.5	No Relaxation	7.0	-	-	-
6	Alkalinity	Mg/L	200	600	80	-	-	-
7	Chlorides (as Cl)	Mg/L	250	1000	26	-	-	-
8	Nitrate as No3	Mg/L	45	45	05	-	-	-
9	Total hardness	Mg/L	200	600	62	-	-	-
10	Calcium as Ca	Mg/L	75	200	14	-	-	-
11	Magnesium as mg	Mg/L	30	100	07	-	-	-
12	Iron	Mg/L	0.3	1.0	0.13	-	-	-
13	Free Chlorine	Mg/L	0.2	1.0	0.0	-	-	-
14	T.D.S.	Mg/L	500	2000	120	-	-	-
15	Fluoride	Mg/L	1.0	1.5	0.14	-	-	-
16	Sulphate sa SO4	Mg/L	200	400	04	-	-	-
<b>BECT. FEACAL TEST</b>								
17	Total Coliform	per 100 ml	Nil		-	-	-	-
18	E Coli or Thermo tolerant coliforms	Per 100 ml	Nil		Nil	-	-	-

- This report should not be provided partially or fully without approval of signatory authorities for legal purposes.
- It is Recommended that acceptable limit is to be implemented values in excess those mentioned under "Acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source, but up to the limits indicated under the "permissible limit in the absence of alternate Source"
- The results refer only to TEST samples and parameters TEST.
- Samples will be stored for a period of 10 days from the date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

*AA*  
Signature of Analyst

District Lab Gwalior

*CHMEST*  
District Water Testing Lab  
P.H.E. Division Gwalior

No. 422 /PHED/ Date :- 14/05/2026

*TSV*  
Lab In charge  
P.H.E.D. Division Gwalior (M.P.)  
P.H.E. Division, Gwalior (M.P.)